

## OFFICE OF THE ILLINOIS STATE FIRE MARSHAL Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)785-1020 or (217)785-5878

FOR OFFICE USE ONLY	
Facility #	
Permit #	

APPLICATION for Permit for <u>UPGRADE OR REPAIR</u> of Underground Storage Tanks. Complete in triplicate (one original and two copies) and file with triplicate site plans, along with an application fee of \$200.00 to: Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, 1035 Stevenson Drive, Springfield, IL 62703.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: (Must be mailing address)  Name					(2) <u>FACILITY</u> - Facility ID #(Name and address where tanks are located:)				
				Name	Name				
Street Address				Street Ad	Street Address				
City	State	Zi	p	City	S	tate Z	Cip Count	y	
Contact Person	 I	Phor	ne	Contact P	erson	P.	hone		
attached docun	CTOR: I certify unnents, and that based bmitted is true, accurate	d on my inquiry of	f those individuals						
Company Nam	e			Address					
City S			State	zip					
Telephone #		Fax #		Contracto	r License # IL_	Expi	ration Date		
Name of Autho	orized Representativ	/e		Title	e or Position				
Signature				Date _					
(4) SITE STA	TUS - Check one:	Existi	ng Site Eme	rgency Repair	Previously Re	quested			
(5) <u>TYPE OF</u>	SYSTEM - Check	whichever applies	- Separate inform	nation is required	for each type o	of system:			
	Fuel Waste Oil   explain)					d Checklist for M	farinas Hazard	ous Substance	
( <b>6</b> ) Provide a <b>S</b>	UMMARY OF W	ORK to be perfor	med and explain a	any unusual circu	imstances on a	separate sheet.			
(7) <u>GENERAL</u> (a) TANK(	L INFORMATION S):		ver applies and fill al sheet(s) if more			e UST system(s)	that will be involv	ed.	
Tank ID#	Capacity in Gallons	Product	Double Wall	Composite	FRP	STI P3 Steel	Manufacturer	Length of Warranty	
								·	
(b) ISLANDS: c) CANOPY: Use this space	= ~	nain Installir		onstructing (expla acing (explain be		None None			

The OSFM REQUIRES the disclosure of the requested information to issue this permit, pursuant to 430 ILCS, Act 15, Gasoline Storage Act. Failure to provide the requested information will result in this permit application not being processed. Such failure will result in the application being returned - it will be returned to the applicant only once (without being denied) and if resubmitted, is REQUIRED to be done within 14 days from the date of return.

(8) <u>TANK(S) COMPLIANCE INFORMATION</u> - (New tanks must be U.L. approved. Used tanks must have OSFM approved recertification). Check whichever applies and use the space provided to describe the work to be performed or the methods to be used and <b>give the manufacturer and model of any equipment,</b> consoles, probes, sensors, etc. to be installed ( <b>do not give catalog numbers</b> ). Attach additional sheet(s) if more space is needed.
(a) RELEASE DETECTION: Manual Tank Gauging Automatic Tank Gauging Interstitial Monitoring Other (explain below)
Equipment and/or explanation:
(b) CORROSION PROTECTION: STI-P3 Composite Fiberglass Other (explain below) Note: CP Equip must use CP App.
(c) SPILL PREVENTION: Spill Containment Manhole Field Constructed Containment Other (explain below) Equipment and/or explanation:
(d) OVERFILL PREVENTION: Drop Tube Valve Float Vent Valve Alarm and/or shutoff Other (explain below) Equipment and/or explanation:
(9) PIPING COMPLIANCE INFORMATION - Check whichever applies and use the space provided to describe the work to be performed or the methods to be used and give the manufacturer and model of any equipment, consoles, probes, sensors, etc. to be installed (do not give catalog numbers). Indicate manufacturer of product piping, vent piping and remote fills. Attach additional sheet(s) if more space is needed.  (a) PIPING: Single Wall Double Wall Fiberglass Steel Other  Existing to remain Installing new Installing partial Note: Removal or Abandonment Permit may be required Equipment and/or explanation
(b) RELEASE DETECTION:
1. Pressurized Piping: Line Leak Detector with Annual Line Test Continuous Line Pressure Monitor Interstitial Monitoring Groundwater Monitoring Vapor Monitoring Other (explain below)
2. Suction Piping:
Equipment and/or explanation:
(c) CORROSION PROTECTION: Dielectric Coating Sacrificial Anode(s) Impressed Current Fiberglass Other (explain below)
(Installation of Cathodic Protection Equipment must be submitted on a Cathodic Protection Application)  Equipment and/or explanation:
(10) THIRD PARTY LISTING OR MANFACTURER DOCUMENTAITON - SEE ATTACHED 3 <sup>RD</sup> PAGE FOR REQUIREMENTS  Does submittal include written documentation for all equipment being installed indicating that the equipment is third party listed for its intended use?  \[ \text{Yes} \] No  Does submittal include documentation from the equipment manufacturers that indicates that the equipment being installed is compatible for its intended use?  \[ \text{Yes} \] No
(11) <u>SITE PLANS</u> - Drawings of the site must accompany the application forms. They must show the entire UST system (tanks, piping, vents, islands, dispensers or other appurtenances) in relation to all buildings, structures and objects with specified setback distances. All objects on the site plans must be named and must be labeled as existing or as proposed. Site plans are not required if only installing equipment for leak detection (except monitoring wells), or spill & overfill prevention. The maximum site plans size allowed is 8 1/2" x 11". Blueprints are not acceptable.
(12) MINIMUM SETBACKS - Clearance distances must be given on the site plans in dimensions from the UST system to all buildings, structures and objects with a setback requirement. The minimum setback requirements for all tanks and all piping are at least:
Yes No  20 feet to property lines or right of way lines
20 feet to storm sewers lines, sanitary sewer lines or similar underground drainage systems 20 feet to basements or similar underground structures 300 feet to any mine shaft, air or escape shaft to a mine 85 feet to any school, institution, public assembly or theater occupancy 400 feet to any potable wells on or near this facility. If no contact IEPA Groundwater section at (217)785-4787
85 feet to any school, institution, public assembly or theater occupancy
400 feet to any potable wells on or near this facility. If no, contact IEPA Groundwater section at (217)785-4787.
It must be noted on the site plans if none of the above apply to this site! There may be provisions to alter these requirements if certain conditions exist under 41 Ill. Adm.Code 175 or if conditions are to remain existing.
(13) <u>AUXILIARY INFORMATION</u> - Other supplemental information, detail drawings or supporting documents may be necessary depending on the type and complexity of the project.
(14) <u>APPLICATION REJECTION</u> - Insufficient information or illegibility can be cause for return or denial.
(15) <u>PERMIT TO WORK</u> - No work can proceed without a granted permit in hand and must be available upon request of the OSFM Storage Tank Safety Specialist.
(16) <u>APPLICANT</u> - The <i>RESPONSIBLE CONTRACTOR</i> must complete this application. A fee of \$200.00 for each site must accompany this application. (Checks or money orders are to be made payable to the Office of the State Fire Marshal. Do not send cash.)

## **Attachment**

## UST System Components That May Be Affected by Biofuel Blends

To be in compliance with USEPA's Final Guidance on "Compatibility of Underground Storage Tank Systems with Biofuel Blends" (USEPA 40 CRF 280.32) dated July 5, 2011, owners and operators of UST systems storing ethanol-blended fuels greater than 10 percent ethanol or biodiesel-blended fuels greater than 20 percent biodiesel must use compatible equipment. EPA considers the following parts of the UST system to be critical for demonstrating compatibility:

- Tank or internal tank lining
- Piping
- Line leak detector
- Flexible connectors
- Drop tube
- Spill and overfill prevention equipment
- Sealants (including pipe dope and thread sealant), fittings, gaskets, o-rings, bushings, couplings, and boots
- Containment sumps (including submersible turbine sumps and under dispenser containment)
- Release detection floats, sensors, and probes
- Fill and riser caps
- Product shear valve

For newly installed equipment comprised of multiple individual components such as submersible turbine pump assemblies, UST system owners and operators may obtain a certification from the equipment manufacturer documenting compatibility for the entire assembly.

## Options for Meeting the Compatibility Requirement

Acceptable methods for owners and operators of UST systems storing ethanol-blended fuels greater than 10 percent ethanol or biodiesel-blended fuels greater than 20 percent biodiesel to demonstrate compatibility under USEPA 40 CFR 280.32 are:

- Use components that are certified or listed by a nationally recognized, independent testing laboratory (for example, Underwriters Laboratories) for use with the fuel stored.
- Use components approved by the manufacturer to be compatible with the fuel stored. EPA considers acceptable forms of manufacturer approvals to:

Be in writing;

Indicate an affirmative statement of compatibility;

Specify the range of biofuel blends the component is compatible with; and

Be from the equipment manufacturer, not another entity (such as the installer or distributor).

 Go to <u>www.epa.gov/oust/altfuels/biofuels.htm</u> for a list of compatibility tested components compiled by USEPA